



NLCS International Malta Office

San Gwann – Malta

Tel: +356 79736657

Email: info.nlcsmalta@gmail.com

Tender Correction

T079

Battery amps is missing from the tender docs by mistake

Must be 60 to 75 amps

Regards

